

Hertfordshire County Scout Council

Lochearnhead Scout Station

Building Risk Assessment



- | | | | | |
|----------|---|---|----------|-------------------|
| 1 | Activity Area | Pullman Rooms | | |
| | Frequency of use | As booked | | |
| 2 | Personnel Involved | Instructors/Staff/Campers/Visitors | | |
| | Number of people | 1- 14 | | |
| 3 | Potential Hazards | | 4 | Risk Level |
| | 1 Uneven, wet surfaces | | | Medium |
| | 2 Fire | | | Low |
| | 3 Electrical appliances | | | Low |
| | 4 Cleaning Equipment and chemicals | | | Low |
| | 5 Working at height | | | Low |
| | 6 Heaters – Contact & Risk of fire | | | Medium |
| 5 | Measures Taken to Control Hazards | | | |
| | 1 Ensure floor area kept clear, obstructions tidied away, spills cleared and floors allowed to dry after cleaning. Ensure external areas at risk are well lit at night. | | | |
| | 2 Ensure combustible material cleared regularly, fire extinguishers in place and sources of ignition controlled | | | |
| | 3 Use as per manufacturer’s instructions, PAT regime in place, minimise trailing cables, do not overload fuses, appropriate trips on circuits. Campers advised of protocol prior to camp. | | | |
| | 4 Store cleaning materials in designated areas, chemicals secured, COSHH and product specific training as appropriate. Remove industrial chemicals from buildings before public use. | | | |
| | 5 Use access equipment appropriate to job and for which training has been given | | | |
| | 6 Signage in place to warn of risk from contact and advising not to cover. | | | |

Compilation date - September 2024 Review period - 12 Months Reference Number - LOCH/B006	Compiled by: KP Reviewed by: DS
--	------------------------------------